CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company

NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

QC ABSTRACT

Nameof Work: Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

SI. No.	Item	Quantity As Per BOQ	Required No's of testes as per Frequency	Actual No's of testes as per Frequency	Testes Results
1	Materials	–	1	1	Pass
2	M20	–	1	1	Pass
3	Stainless Steel	–	1	1	Pass

Cubes

0-5 Cum 1Set
6-15 Cum 2Set
16-30 Cum 3Set
31-50 Cum 4Set
Add 1set for extra 50Cum

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

A.E.E

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2023-24 Date: 22.02.2023

TEST REPORT ON CEMENT

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore
Agency **Sri. Manoj Naik B M,** Contractor, Bangalore
Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore
Sample ID: : Cement (Birla Super 53 grade OPC)
Sample Supplied by: : AGENCY
Date of Manufacture: Jan-23
Date of Testing 20.02.2023 to 22.02.2023

Sl.No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 269:2015
1	a) Initial Setting Time	IS-4031 (Part - 5):1988(RA 2014)	135 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part - 5):1988(RA 2014)	325 Minutes	Not More than 600 Minutes
2	Soundness	IS-4031 (Part 3) :1988 (RA 2014) by the Le-Chatelier method	1 mm	Not more than 10 mm
3	Standard Consistency	IS-4031 (Part -4)	28.50%	-

A.E.E

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date: 22.02.2023

TEST REPORT ON CEMENT

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore
Agency **Sri. Manoj Naik B M,** Contractor, Bangalore
Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore
Sample ID: : Cement (Birla Super 53 grade OPC)
Sample Supplied by: : AGENCY
Date of Manufacture: Jan-23
Date of Testing 20.02.2023 to 22.02.2023

Sl.No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 269:2015
1	a) Initial Setting Time	IS-4031 (Part - 5):1988(RA 2014)	135 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part - 5):1988(RA 2014)	325 Minutes	Not More than 600 Minutes
2	Soundness	IS-4031 (Part 3) :1988 (RA 2014) by the Le-Chatelier method	1 mm	Not more than 10 mm
3	Standard Consistency	IS-4031 (Part -4)	28.50%	-

A.E.E

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date 22.02.2023

TEST REPORT ON FINE AGGREGATES (SAND)

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore
Agency **Sri. Manoj Naik B M,** Contractor, Bangalore
Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore
Date of Testing 22.02.2023
IS Code : IS 383:2016
: IS 2386 (Part 1):1963(RA 2011)
Material : Sand Total Wt. of Aggregates in gms **1000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Requirements as per IS 383:2016 Spec.Limits For Zone-II
10	0	0	0	100	100
4.75	85	8.50	8.50	91.5	90-100
2.36	114	11.40	19.90	80.1	75-100
1.18	189	18.90	38.80	61.2	55-90
600 Micron	225	22.50	61.30	38.7	35-59
300 Micron	136	13.60	74.90	25.1	8-30
150 Micron	189	18.90	93.80	6.2	0-10

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company

NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date 22.02.2023

TEST REPORT ON COARSE AGGREGATES

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Date of Testing 22.02.2023

IS Code : IS 383:2016

: IS 2386 (Part 1):1963(RA 2011)

Material : 20mm Aggregates

Total Wt. of Aggregates in gms= **5000**

Is Sieve Size in mm	Weight Retained (gm)	Retained Weight in %	Cumulative Retained Weight in %	Cumulative Weight Passing in %	Requirements as per IS 383:2016
40	0	0	0	100	100
20	206	4.1	4.1	95.9	95-100
10	2897	57.9	62.1	37.9	25-55
4.75	1699	34.0	96.0	4.0	0-10

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company

NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date 28.02.2023

TEST REPORT OF PHYSICAL PROPERTIES OF STAINLESS STEEL

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Reference to BIS codes: IS 6911:1992

IS 1608:2005 Metallic Materials- Tensile Testing at Ambient Temperature

Date of test: 28.02.2023

Tensile Test:

Nominal size (dia in mm)	50mm	Limits as Per IS 6911 :1992
0.20 % proof stress/ yield stress (N/mm^2)	252	200 Min
Tensile strength (N/mm^2)	438	400 Min
Elongation, percent in Min in 50mm	42	40 Min

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date 28.02.2023

TEST REPORT OF PHYSICAL PROPERTIES OF STAINLESS STEEL

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Reference to BIS codes: IS 6911:1992

IS 1608:2005 Metallic Materials- Tensile Testing at Ambient Temperature

Date of test: 28.02.2023

Tensile Test:

Nominal size (dia in mm)	38 mm	Limits as Per IS 6911 :1992
0.20 % proof stress/ yield stress (N/mm^2)	256	200 Min
Tensile strength (N/mm^2)	441	400 Min
Elongation, percent in Min in 50mm	45	40 Min

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS-

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date 28.02.2023

TEST REPORT OF PHYSICAL PROPERTIES OF STAINLESS STEEL

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of Work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Reference to BIS codes: IS 6911:1992

IS 1608:2005 Metallic Materials- Tensile Testing at Ambient Temperature

Date of test: 28.02.2023

Tensile Test:

Nominal size (dia in mm)	15*20*1.2 mm	Limits as Per IS 6911 :1992
0.20 % proof stress/ yield stress (N/mm^2)	227	200 Min
Tensile strength (N/mm^2)	431	400 Min
Elongation, percent in Min in 50mm	44	40 Min

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date: 09.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	**Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore
Agency	**Sri. Manoj Naik B M,** Contractor, Bangalore
Name of the work	Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	02.03.2023	09.03.2023	8.065	395.5	17.58
2	02.03.2023	09.03.2023	8.220	380.1	16.89
3	02.03.2023	09.03.2023	8.198	376.9	16.75

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date: 09.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client	**Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore
Agency	**Sri. Manoj Naik B M,** Contractor, Bangalore
Name of the work	Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore
Sample ID	: Cement Concrete
Size of cubes	: 150mmx150mmx150mm
Cross Sectional Area	: 22500 mm^2
Technical Reference	: IS: 516-1959 (Reaffirmed 2008)
Grade of Concrete	: M_{20}
Compressive Strength as on	: 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	02.03.2023	09.03.2023	8.163	379.6	16.87
2	02.03.2023	09.03.2023	8.202	385.2	17.12
3	02.03.2023	09.03.2023	8.145	371.6	16.52

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date: 10.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of the work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on : 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	03.03.2023	10.03.2023	8.214	372.6	16.56
2	03.03.2023	10.03.2023	8.156	380.9	16.93
3	03.03.2023	10.03.2023	8.203	399.2	17.74

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23 Date: 30.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of the work Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on :28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	02.03.2023	30.03.2023	8.145	526.3	23.39
2	02.03.2023	30.03.2023	8.199	545.9	24.26
3	02.03.2023	30.03.2023	8.202	538.1	23.92

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23

Date: 30.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency : **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of the work : Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on :28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	02.03.2023	30.03.2023	8.165	536.2	23.83
2	02.03.2023	30.03.2023	8.202	542.1	24.09
3	02.03.2023	30.03.2023	8.145	528.9	23.51

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

A.E.E

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com

CIVIL AIM CONSULTANTS & ENGINEERS

(Building Geo-Tech & Highway Materials Testing Laboratory)

An ISO 9001-2015 Certified Company
NABL Accredited As Per ISO/IEC 17025:2017 Laboratory

Job No.: CACE/BBMP/MNBM/02/2022-23

Date: 31.03.2023

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client — **Assistant Executive Engineer, Yelahanka** sub division, BBMP, Banglore

Agency — **Sri. Manoj Naik B M,** Contractor, Bangalore

Name of the work — Providing and fixing Street name boards at Chowdeshwari ward no.02 of Yelahanka sub division, BBMP, Bangalore

Sample ID : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{20}

Compressive Strength as on :28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	03.03.2023	31.03.2023	8.175	536.5	23.84
2	03.03.2023	31.03.2023	8.266	524.1	23.29
3	03.03.2023	31.03.2023	8.202	543.9	24.17

Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples collected at the site
3. Any Query regarding the report must be reported within 30 days from the date of testing.

For CIVIL AIM CONSULTANTS & ENGINEERS

Authorised Signatory

No. 01, Satvika Nilaya, Opp. Widia Poorna Prajna School,
Ramaiah Layout, Nagasandra, Bangalore - 560 073.
Ph: 9591618639, GSTIN: 29CNWPD9510K1ZB, Email: civilaimconsultants@gmail.com